



MICHIGAN DEPARTMENT OF ENVIRONMENTAL QUALITY
DRINKING WATER AND MUNICIPAL ASSISTANCE DIVISION

2018 WATER SUPPLY CROSS CONNECTION REPORT

Issued under authority of 1976 PA 399, as amended, MCL 325.1001 et seq., and its administrative rules.
Failure to submit this form is a violation of the Act and may subject the water supply to enforcement actions.

Return the completed form by March 31, 2019 to the appropriate Department of Environmental Quality (DEQ) district office to comply with administrative Rule R 325.11405 that states "a water utility shall report annually to the department on the status of the cross connection control program on a form provided by the department." For district office addresses, visit https://www.michigan.gov/deq and click on Water>Drinking Water>Community Water Supply>District Offices Map and Contact Information.

WSSN: 7231

A. Name of water system: Yankee Springs Township County: Barry

B. Year that the current written cross connection control program was approved by DEQ: 2001

C. Total number of industrial, commercial, institutional, residential, and governmental accounts that must be routinely reinspected for cross connections: 9

Of this number,

- How many are High Hazard accounts: 3 Frequency of Reinspection: Once per Year

- How many are Low Hazard accounts: 6 Frequency of Reinspection: Once per Year

D. Number of accounts from line "C" that received an initial inspection in 2018: 1

E. Total number of reinspections required and completed in 2018 based on degree of hazard:

- High hazard reinspections required: 3 High hazard reinspections completed: 2

- Low hazard reinspections required: 6 Low hazard reinspections completed: 6

F. Number of accounts where a cross connection(s) was found to exist during inspections or reinspections in 2018: 1

G. Number of accounts from line "F" where corrective actions have been completed: 0

H. Total number of accounts from line "C" which are now in compliance with the local cross connection control program; H = C - (F - G): 8

I. Total number of backflow prevention devices in system requiring testing: 3

J. Number of backflow prevention devices tested in 2018: 0

Outline briefly any changes or significant findings since last reporting. Use additional sheets if necessary.

Narrative Description of Program:

The Yankee Springs Car Wash had the backflow preventer freeze during the winter and the water service is currently shut off until repairs are made. (High Hazard)

Name: Larry Knowles

Title: Director Date: 3/19/19