

ANALYTICAL RESULTS

Project: Yankee Springs TWP Water WSSN

Pace Project No.: 50297655

Sample: DBP1 - 12920 Park Dr. Barry CO **Lab ID: 50297655001** Collected: 09/14/21 14:59 Received: 09/17/21 14:05 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
552.3 Haloacetic Acids								
Analytical Method: EPA 552.3 Preparation Method: EPA 552.3								
Pace Analytical Services - Ormond Beach								
Dibromoacetic Acid	ND	ug/L	1.0	1	09/23/21 11:55	09/24/21 13:01	631-64-1	
Dichloroacetic Acid	ND	ug/L	1.0	1	09/23/21 11:55	09/24/21 13:01	79-43-6	
Haloacetic Acids (Total)	1.1	ug/L	1.0	1	09/23/21 11:55	09/24/21 13:01		
Monobromoacetic Acid	ND	ug/L	1.0	1	09/23/21 11:55	09/24/21 13:01	79-08-3	
Monochloroacetic Acid	ND	ug/L	1.0	1	09/23/21 11:55	09/24/21 13:01	79-11-8	
Trichloroacetic Acid	1.1	ug/L	1.0	1	09/23/21 11:55	09/24/21 13:01	76-03-9	
Surrogates								
2,3-Dibromopropanoic Acid (S)	94	%	70-130	1	09/23/21 11:55	09/24/21 13:01	600-05-5	
524.2 MSV								
Analytical Method: EPA 524.2								
Pace Analytical Services - Indianapolis								
Bromochloromethane	ND	ug/L	1.0	1		09/24/21 20:45	74-97-5	N2
Bromodichloromethane	6.0	ug/L	0.50	1		09/24/21 20:45	75-27-4	N2
Bromomethane	ND	ug/L	5.0	1		09/24/21 20:45	74-83-9	L1,N2
Chloromethane	ND	ug/L	1.0	1		09/24/21 20:45	74-87-3	N2
Dibromochloromethane	5.9	ug/L	1.0	1		09/24/21 20:45	124-48-1	N2
1,2-Dibromoethane (EDB)	ND	ug/L	1.0	1		09/24/21 20:45	106-93-4	N2
Dibromomethane	ND	ug/L	0.50	1		09/24/21 20:45	74-95-3	N2
Dichlorodifluoromethane	ND	ug/L	1.0	1		09/24/21 20:45	75-71-8	N2
Total Trihalomethanes (Calc.)	11.9	ug/L	2.0	1		09/24/21 20:45		N2
Trichlorofluoromethane	ND	ug/L	0.50	1		09/24/21 20:45	75-69-4	N2
Surrogates								
4-Bromofluorobenzene (S)	100	%	70-130	1		09/24/21 20:45	460-00-4	
Dibromofluoromethane (S)	98	%	70-130	1		09/24/21 20:45	1868-53-7	
Toluene-d8 (S)	100	%	70-130	1		09/24/21 20:45	2037-26-5	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: Yankee Springs TWP Water WSSN

Pace Project No.: 50297655

Sample: TP100 WellHouse Treat **Lab ID:** 50297655002 Collected: 09/17/21 12:25 Received: 09/17/21 14:05 Matrix: Drinking Water
PlantTap

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
4500-NO3 F NO2/NO3 unpres		Analytical Method: SM 4500-NO3 F-11 Pace Analytical Services - Grand Rapids						
Nitrogen, NO2 plus NO3	ND	mg/L	0.050	1		09/17/21 16:42		
Nitrogen, Nitrate	ND	mg/L	0.050	1		09/17/21 16:42	14797-55-8	
Nitrogen, Nitrite	ND	mg/L	0.010	1		09/17/21 16:42	14797-65-0	M1

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.